



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**N-14**

**Lab# 2785**

**Customer**

**Facility Name:** *Quality Inn Cranberry*

**Address:** *30 St. Francis Way  
Cranberry, PA 16066*

**Matrix:** *Recreational Water*

**Source Type:** *Pool*

**Sample Collection**

**Date:** *6/30/25*

**Time:** *10:10 AM*

**Method:** *Grab*

**Sample Final Analysis**

**Date:** *7/3/25*

**Time:** *9:30 AM*

**Analyst:** *AS*

<b>Accredited Analysis</b>	<b>Results</b>	<b>Reporting limit</b>	<b>Incubation Date/Time</b>		<b>Analyst</b>	<b>Method</b>
Escherichia Coli:	Absent	Absent	7/1/25	9:00 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/1/25	9:00 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	6/30/25	3:15 PM	EB	SM 9215B

<b>Field Analysis</b>	<b>Results</b>	<b>Reporting limit</b>	<b>Date/Time</b>		<b>Analyst</b>	<b>Method</b>
pH:	7.0 SU	7.2 - 7.8 SU	6/30/25	10:10 AM	ZR	DPD
Chlorine:	7.5 mg/l	1.0 - 5.0 mg/l	6/30/25	10:10 AM	ZR	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/30/25	10:10 AM	ZR	Visual

**Sample comments**

\_\_\_\_\_  
Andre Smith, Lead Supervisor

*Andre Smith*

( When exceeding reporting limit pool or spa is unfit)



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**N-14**

**Lab# 2785**

**Customer**

**Facility Name:** *Quality Inn Cranberry*

**Address:** *30 St. Francis Way  
Cranberry, PA 16066*

**Matrix:** *Recreational Water*

**Source Type:** *Pool*

**Sample Collection**

**Date:** *6/30/25*

**Time:** *10:10 AM*

**Method:** *Grab*

**Sample Final Analysis**

**Date:** *7/3/25*

**Time:** *9:30 AM*

**Analyst:** *AS*

<b>Accredited Analysis</b>	<b>Results</b>	<b>Reporting limit</b>	<b>Incubation Date/Time</b>		<b>Analyst</b>	<b>Method</b>
Escherichia Coli:	Absent	Absent	7/1/25	9:00 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/1/25	9:00 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	6/30/25	3:15 PM	EB	SM 9215B

<b>Field Analysis</b>	<b>Results</b>	<b>Reporting limit</b>	<b>Date/Time</b>		<b>Analyst</b>	<b>Method</b>
pH:	7.0 SU	7.2 - 7.8 SU	6/30/25	10:10 AM	ZR	DPD
Chlorine:	7.5 mg/l	1.0 - 5.0 mg/l	6/30/25	10:10 AM	ZR	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/30/25	10:10 AM	ZR	Visual

**Sample comments**

\_\_\_\_\_  
Andre Smith, Lead Supervisor

*Andre Smith*

( When exceeding reporting limit pool or spa is unfit)