



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

E - 10

Lab# 2311

Customer

Facility Name: Lake Ridge
Address: Lakeridge Drive
Greensburg, PA 15601

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 6/10/25
Time: 10:15 AM
Method: Grab

Sample Final Analysis

Date: 6/13/25
Time: 9:30 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	6/11/25	10:00 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/11/25	10:00 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	6/10/25	3:12 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	7.6 SU	7.2 - 7.8 SU	6/10/25	10:15 AM	JC	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	6/10/25	10:15 AM	JC	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/10/25	10:15 AM	JC	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

E - 10

Lab# 2311

Customer

Facility Name: Lake Ridge
Address: Lakeridge Drive
Greensburg, PA 15601

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 6/10/25
Time: 10:15 AM
Method: Grab

Sample Final Analysis

Date: 6/13/25
Time: 9:30 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	6/11/25	10:00 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/11/25	10:00 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	6/10/25	3:12 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	7.6 SU	7.2 - 7.8 SU	6/10/25	10:15 AM	JC	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	6/10/25	10:15 AM	JC	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/10/25	10:15 AM	JC	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor