



Dream Pools and Spas  
1105 Washington Blvd  
Pittsburgh, Pennsylvania 15206  
(412) 661- 7665

Lab ID No. 02-04041

W-2

Lab# 282

## Laboratory Analysis Report

### Customer

Facility Name: South Fayette High School

Address: 3640 Old Oakdale Rd.  
MC Donald, PA 15057

Matrix: Recreational Water

Source Type: Shallow End

### Sample Collection

Date: 2/10/26

Time: 9:30 AM

Method: Grab

### Sample Final Analysis

Date: 2/13/26

Time: 10:30 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	2/11/26	10:00 AM	JC	SM 9222G
Total coliforms:	0/100mls	2/100mls	2/11/26	10:00 AM	JC	SM 9222B
Standard plate count:	0/ml	200/ml	2/10/26	3:20 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	2/10/26	9:30 AM	VH	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	2/10/26	9:30 AM	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	2/10/26	9:30 AM	VH	Visual

### Sample comments

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor