

Dreams Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665

Lab# 213

PPS

Laboratory Analysis Report

CustomerSample CollectionFacility Name:Langley High SchoolDate:8/18/25Time:2:51 PMAddress:2940 Sheradan Blvd.Method:GrabPittsburgh, PA 15204

Matrix: Recreational Water Sample Final Analysis
Date: 8/21/25
Time: 9:00 AM

Source Type: Pool Shallow Analyst: AS

Accredited Analysis	Results	Rating	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Α	8/19/25	10:00 AM	EB	SM 9222G
Total coliforms:	0/100mls	Α	8/19/25	10:00 AM	EB	SM 9222B
Standard plate count:	0/ml	Α	8/18/25	4:20 PM	EB	SM 9215B

Field Analysis	Results	Rating	I	Date/Time	Analyst	Method
pH:	7.5 SU	Α	8/18/25	2:51 PM	ZS	DPD
Chlorine:	4.0 mg/l	В	8/18/25	2:51 PM	ZS	DPD
Turbidity:	1 NTU	Α	8/18/25	2:51 PM	ZS	Visual

Sample comments

andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor