



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-2

Lab# 297

Customer

Facility Name: Steel Valley High School

Address: 3113 Main Street
Munhall, PA 15120

Matrix: Recreational Water

Source Type: Pool Shallow

Sample Collection

Date: 12/8/25

Time: 8:35 AM

Method: Grab

Sample Final Analysis

Date: 12/11/25

Time: 10:30 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	12/9/25	11:10 AM	JC	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/9/25	11:10 AM	JC	SM 9222B
Standard plate count:	0/ml	200/ml	12/8/25	5:30 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit		Date/Time	Analyst	Method
pH:	8.2 SU	7.2 - 7.8 SU	12/8/25	8:35 AM	SH	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	12/8/25	8:35 AM	SH	DPD
Turbidity:	1 NTU	1 - 2 NTU	12/8/25	8:35 AM	SH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor