



**Dream Pools And Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**APM 2**

**Lab# 2189**

**Customer**

*American Pools Management*  
*3261 Babcock Blvd.*  
*Pittsburgh, PA 15237*

**Sample Collection**

*Facility Name: Forest Glen*

*Date: 5/27/25*

*Time: 11:30 AM*

*Address: 1514 Forest Green Dr.*  
*Moon, PA 15108*

*Method: Grab*

**Sample Final Analysis**

*Matrix: Recreational Water*

*Date: 5/30/25*

*Time: 9:00 AM*

*Source Type: Pool*

*Analyst: AS*

<b>Accredited Analysis</b>	<b>Results</b>	<b>Reporting limit</b>	<b>Incubation</b>	<b>Date/Time</b>	<b>Analyst</b>	<b>Method</b>
Escherichia Coli:	Absent	Absent	5/28/25	9:15 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	5/28/25	9:15 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	5/27/25	2:55 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	7.6 SU	7.2 - 7.8 SU	5/27/25	11:30 AM	VH	DPD
Chlorine:	10.0 mg/l	1.0 - 5.0 mg/l	5/27/25	11:30 AM	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	5/27/25	11:30 AM	VH	Visual

**Sample comments**

*Andre Smith*

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



**Dream Pools And Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**APM 2**

**Lab# 2189**

**Customer**

*American Pools Management*  
*3261 Babcock Blvd.*  
*Pittsburgh, PA 15237*

**Sample Collection**

*Facility Name: Forest Glen*

*Date: 5/27/25*

*Time: 11:30 AM*

*Address: 1514 Forest Green Dr.*  
*Moon, PA 15108*

*Method: Grab*

**Sample Final Analysis**

*Matrix: Recreational Water*

*Date: 5/30/25*

*Time: 9:00 AM*

*Source Type: Pool*

*Analyst: AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	5/28/25 9:15 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	5/28/25 9:15 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	5/27/25 2:55 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	5/27/25 11:30 AM	VH	DPD
Chlorine:	10.0 mg/l	1.0 - 5.0 mg/l	5/27/25 11:30 AM	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	5/27/25 11:30 AM	VH	Visual

**Sample comments**

*Andre Smith*

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor