



Dream Pools and Spas  
1105 Washington Blvd  
Pittsburgh, Pennsylvania 15206  
(412) 661- 7665

Lab ID No. 02-04041

W-2

Lab# 413

## Laboratory Analysis Report

### Customer

Facility Name: Town Place Airport  
Address: 1006 Sutherland Dr.  
Pittsburgh, PA 15205

Matrix: Recreational Water

Source Type: Pool

### Sample Collection

Date: 10/21/25  
Time: 12:00 PM  
Method: Grab

### Sample Final Analysis

Date: 10/24/25  
Time: 10:00 AM  
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	10/22/25	9:30 AM	JC	SM 9222G
Total coliforms:	0/100mls	2/100mls	10/22/25	9:30 AM	JC	SM 9222B
Standard plate count:	0/ml	200/ml	10/21/25	3:00 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.2 SU	7.2 - 7.8 SU	10/21/25	12:00 PM	VH	DPD
Chlorine:	10.0 mg/l	1.0 - 5.0 mg/l	10/21/25	12:00 PM	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	10/21/25	12:00 PM	VH	Visual

### Sample comments

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor