



Dream Pools And Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 1

Lab# 2010

Customer *American Pools Management*
3261 Babcock Blvd.
Pittsburgh, PA 15237

Sample Collection

Facility Name: *Adams Ridge*

Date: *7/29/25*

Address: *100 Adams Ridge Blvd.*
Mars, PA 16046

Time: *3:51 PM*

Method: *Grab*

Sample Final Analysis

Matrix: *Recreational Water*

Date: *8/1/25*

Source Type: *Baby Pool*

Time: *9:00 AM*

Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/30/25	10:30 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/30/25	10:30 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	7/29/25	4:30 PM	0	SM 9215B
Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.2 SU	7.2 - 7.8 SU	7/29/25	3:51 PM	ZR	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	7/29/25	3:51 PM	ZR	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/29/25	3:51 PM	ZR	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dream Pools And Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 1

Lab# 2010

Customer

American Pools Management
3261 Babcock Blvd.
Pittsburgh, PA 15237

Sample Collection

Facility Name: Adams Ridge

Date: 7/29/25

Address: 100 Adams Ridge Blvd.
Mars, PA 16046

Time: 3:51 PM

Method: Grab

Sample Final Analysis

Matrix: Recreational Water

Date: 8/1/25

Source Type: Baby Pool

Time: 9:00 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/30/25	10:30 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/30/25	10:30 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	7/29/25	4:30 PM	0	SM 9215B
Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.2 SU	7.2 - 7.8 SU	7/29/25	3:51 PM	ZR	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	7/29/25	3:51 PM	ZR	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/29/25	3:51 PM	ZR	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor