



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

E - 11

Lab# 2315

Customer

Facility Name: Laurel Mountain

Address: 421 Weaver Mill Road
Rector, PA 15677

Matrix: Recreational Water

Source Type: Slide Pool

Sample Collection

Date: 5/27/25

Time: 12:50 PM

Method: Grab

Sample Final Analysis

Date: 5/30/25

Time: 9:00 AM

Analyst: AS

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | | Analyst | Method |
|-----------------------|----------|-----------------|----------------------|---------|---------|----------|
| Escherichia Coli: | Absent | Absent | 5/28/25 | 9:45 AM | EB | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 5/28/25 | 9:45 AM | EB | SM 9222B |
| Standard plate count: | 300/ml | 200/ml | 5/27/25 | 5:40 PM | AS | SM 9215B |

| Field Analysis | Results | Reporting limit | Date/Time | | Analyst | Method |
|----------------|----------|-----------------|-----------|----------|---------|--------|
| pH: | 7.4 SU | 7.2 - 7.8 SU | 5/27/25 | 12:50 PM | JC | DPD |
| Chlorine: | 1.0 mg/l | 1.0 - 5.0 mg/l | 5/27/25 | 12:50 PM | JC | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 5/27/25 | 12:50 PM | JC | Visual |

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

E - 11

Lab# 2315

Customer

Facility Name: Laurel Mountain

Address: 421 Weaver Mill Road
Rector, PA 15677

Matrix: Recreational Water

Source Type: Slide Pool

Sample Collection

Date: 5/27/25

Time: 12:50 PM

Method: Grab

Sample Final Analysis

Date: 5/30/25

Time: 9:00 AM

Analyst: AS

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | | Analyst | Method |
|-----------------------|----------|-----------------|----------------------|---------|---------|----------|
| Escherichia Coli: | Absent | Absent | 5/28/25 | 9:45 AM | EB | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 5/28/25 | 9:45 AM | EB | SM 9222B |
| Standard plate count: | 300/ml | 200/ml | 5/27/25 | 5:40 PM | AS | SM 9215B |

| Field Analysis | Results | Reporting limit | Date/Time | | Analyst | Method |
|----------------|----------|-----------------|-----------|----------|---------|--------|
| pH: | 7.4 SU | 7.2 - 7.8 SU | 5/27/25 | 12:50 PM | JC | DPD |
| Chlorine: | 1.0 mg/l | 1.0 - 5.0 mg/l | 5/27/25 | 12:50 PM | JC | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 5/27/25 | 12:50 PM | JC | Visual |

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor