



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-3

Lab# 048

Customer

Facility Name: Chartiers Valley High School

Address: 50 Thoms Run Rd.
Bridgeville, PA 15017

Matrix: Recreational Water

Source Type: Pool Shallow

Sample Collection

Date: 11/17/25

Time: 1:02 PM

Method: Grab

Sample Final Analysis

Date: 11/20/25

Time: 10:00 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	11/18/25	9:30 AM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	11/18/25	9:30 AM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	11/17/25	4:00 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	11/17/25	1:02 PM	GR	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	11/17/25	1:02 PM	GR	DPD
Turbidity:	1 NTU	1 - 2 NTU	11/17/25	1:02 PM	GR	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)