



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

E - 10

Lab# 079

Customer

Facility Name: Courtyard by Marriott
Address: 700 Powerline Drive
Greensburg, PA 15601

Matrix: Recreational Water

Source Type: Spa

Sample Collection

Date: 5/29/25
Time: 4:15 PM
Method: Grab

Sample Final Analysis

Date: 5/31/25
Time: 3:30 PM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
---------------------	---------	-----------------	----------------------	---------	--------

Escherichia Coli:	Absent	Absent	5/29/25 6:05 PM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	5/29/25 6:05 PM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	5/29/25 6:05 PM	SL	SM 9215B

Additional Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
---------------------	---------	-----------------	----------------------	---------	--------

Fecal Streptococcus	0/100mls	2/100mls	5/29/25 6:05 PM	SL	SM 9230C
---------------------	----------	----------	-----------------	----	----------

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
----------------	---------	-----------------	-----------	---------	--------

pH:	7.6 SU	7.2 - 7.8 SU	5/29/25 4:15 PM	BH	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	5/29/25 4:15 PM	BH	DPD
Turbidity:	1 NTU	1 - 2 NTU	5/29/25 4:15 PM	BH	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

E - 10

Lab# 079

Customer

Facility Name: Courtyard by Marriott
Address: 700 Powerline Drive
Greensburg, PA 15601

Matrix: Recreational Water

Source Type: Spa

Sample Collection

Date: 5/29/25
Time: 4:15 PM
Method: Grab

Sample Final Analysis

Date: 5/31/25
Time: 3:30 PM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
---------------------	---------	-----------------	----------------------	---------	--------

Escherichia Coli:	Absent	Absent	5/29/25 6:05 PM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	5/29/25 6:05 PM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	5/29/25 6:05 PM	SL	SM 9215B

Additional Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
---------------------	---------	-----------------	----------------------	---------	--------

Fecal Streptococcus	0/100mls	2/100mls	5/29/25 6:05 PM	SL	SM 9230C
---------------------	----------	----------	-----------------	----	----------

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
----------------	---------	-----------------	-----------	---------	--------

pH:	7.6 SU	7.2 - 7.8 SU	5/29/25 4:15 PM	BH	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	5/29/25 4:15 PM	BH	DPD
Turbidity:	1 NTU	1 - 2 NTU	5/29/25 4:15 PM	BH	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor