



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM

Lab# 2608

C2

Customer *American Pools Management*
3261 Babcock Blvd.
Pittsburgh, PA 15237

Facility Name: *Yards @ 3 Crossings*

Address: *2645 Railroad St.*
Pittsburgh, PA 15222

Matrix: *Recreational Water*

Source Type: *Spa*

Sample Collection

Date: *11/25/25*

Time: *10:00 AM*

Method: *Grab*

Sample Final Analysis

Date: *11/28/25*

Time: *10:30 AM*

Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	1/0/00 10:00 AM	SL	SM 9222G

Total coliforms:	0/100mls	2/100mls	1/0/00 10:00 AM	SL	SM 9222B
------------------	----------	----------	----------------------	----	----------

Standard plate count:	0/ml	200/ml	1/0/00 4:45 PM	SL	SM 9215B
-----------------------	------	--------	---------------------	----	----------

Additional Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Fecal Streptococcus	0/100mls	2/100mls	11/26/25 10:20 AM	SL	SM 9230C

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	11/25/25 10:00 AM	BH	DPD
Chlorine:	10.0 mg/l	1.0 - 5.0 mg/l	11/25/25 10:00 AM	BH	DPD
Turbidity:	1 NTU	1 - 2 NTU	11/25/25 10:00 AM	BH	Visual

Sample comments

Andre Smith

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)