



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661-7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-16

Lab# 2218

Customer

Facility Name: *Gables at Brickyard Hill*

Address: *1170 Lily Vue Court
Mars, PA 16046*

Matrix: *Recreational Water*

Source Type: *Pool*

Sample Collection

Date: *6/30/25*

Time: *1:46 PM*

Method: *Grab*

Sample Final Analysis

Date: *7/3/25*

Time: *9:30 AM*

Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method	
Escherichia Coli:	Absent	Absent	7/1/25	9:30 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/1/25	9:30 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	6/30/25	3:15 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	7.4 SU	7.2 - 7.8 SU	6/30/25	1:46 PM	GR	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	6/30/25	1:46 PM	GR	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/30/25	1:46 PM	GR	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661-7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-16

Lab# 2218

Customer

Facility Name: *Gables at Brickyard Hill*

Address: *1170 Lily Vue Court
Mars, PA 16046*

Matrix: *Recreational Water*

Source Type: *Pool*

Sample Collection

Date: *6/30/25*

Time: *1:46 PM*

Method: *Grab*

Sample Final Analysis

Date: *7/3/25*

Time: *9:30 AM*

Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method	
Escherichia Coli:	Absent	Absent	7/1/25	9:30 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/1/25	9:30 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	6/30/25	3:15 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	7.4 SU	7.2 - 7.8 SU	6/30/25	1:46 PM	GR	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	6/30/25	1:46 PM	GR	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/30/25	1:46 PM	GR	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor