



Dream Pools And Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 2

Lab# 2149

Customer *American Pools Management*
3261 Babcock Blvd.
Pittsburgh, PA 15237

Facility Name: *Deauville Park Apts*

Address: *540 Deauville Drive*
Monroeville, PA 15146

Sample Collection

Date: *6/17/25*
Time: *12:11 PM*
Method: *Grab*

Matrix: *Recreational Water*

Source Type: *Pool*

Sample Final Analysis

Date: *6/20/25*
Time: *9:00 AM*
Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/18/25	9:30 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/18/25	9:30 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	6/17/25	4:30 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	6/17/25	12:11 PM	EH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	6/17/25	12:11 PM	EH	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/17/25	12:11 PM	EH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dream Pools And Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 2

Lab# 2149

Customer *American Pools Management*
3261 Babcock Blvd.
Pittsburgh, PA 15237

Facility Name: *Deauville Park Apts*

Address: *540 Deauville Drive*
Monroeville, PA 15146

Sample Collection

Date: *6/17/25*
Time: *12:11 PM*
Method: *Grab*

Matrix: *Recreational Water*

Source Type: *Pool*

Sample Final Analysis

Date: *6/20/25*
Time: *9:00 AM*
Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/18/25	9:30 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/18/25	9:30 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	6/17/25	4:30 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	6/17/25	12:11 PM	EH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	6/17/25	12:11 PM	EH	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/17/25	12:11 PM	EH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor