



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661-7665
Laboratory Analysis Report

Lab ID No. 02-04041

LCP

Lab# 2344

Customer

Facility Name: *McKenzie Place*
Address: *2500 Kenzie Drive
Pittsburgh, PA 15205*
Matrix: *Recreational Water*
Source Type: *Pool*

Sample Collection

Date: *9/2/25*
Time: *11:45 AM*
Method: *Grab*

Sample Final Analysis

Date: *9/5/25*
Time: *10:00 AM*
Analyst: *AS*

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	9/3/25	9:30 AM	SL SM 9222G
Total coliforms:	0/100mls	2/100mls	9/3/25	9:30 AM	SL SM 9222B
Standard plate count:	0/ml	200/ml	9/2/25	3:50 PM	AS SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	9/2/25	11:45 AM	VH DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	9/2/25	11:45 AM	VH DPD
Turbidity:	1 NTU	1 - 2 NTU	9/2/25	11:45 AM	VH Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor