



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N - 1

Lab# 436

Customer

Facility Name: Grove City College
Address: 100 Campus Dr.
Grove City, PA 16127

Matrix: Recreational Water

Source Type: Comp Pool

Sample Collection

Date: 12/8/25
Time: 2:05 PM
Method: Grab

Sample Final Analysis

Date: 12/11/25
Time: 11:30 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	12/9/25	11:10 AM	JC	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/9/25	11:10 AM	JC	SM 9222B
Standard plate count:	0/ml	200/ml	12/8/25	5:30 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	12/8/25	2:05 PM	BH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	12/8/25	2:05 PM	BH	DPD
Turbidity:	1 NTU	1 - 2 NTU	12/8/25	2:05 PM	BH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor