



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

E-2

Lab# 251

Customer

Facility Name: Penn Trafford High School

Address: 3381 Rt. 130
Harrison City, PA 15636

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 9/2/25

Time: 1:27 PM

Method: Grab

Sample Final Analysis

Date: 9/5/25

Time: 10:00 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	9/3/25	10:00 AM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	9/3/25	10:00 AM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	9/2/25	3:50 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit		Date/Time	Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	9/2/25	1:27 PM	JC	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	9/2/25	1:27 PM	JC	DPD
Turbidity:	1 NTU	1 - 2 NTU	9/2/25	1:27 PM	JC	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor