



**Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661-7665**

Laboratory Analysis Report

Lab ID No. 02-04041

C-1

Lab# 349

<u>Customer</u>		<u>Sample Collection</u>				
Facility Name:	Courtyard - University Center	Date:	1/13/26			
Address:	100 Lytton Ave. Pittsburgh, PA 15213	Time:	1:47 PM			
<u>Sample Final Analysis</u>						
Matrix:	Recreational Water	Date:	1/16/26			
Source Type:	Pool	Time:	11:30 AM			
		Analyst:	AS			
Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method	
Escherichia Coli:	Absent	Absent	1/14/26	11:00 AM	JC	SM 9222G
Total coliforms:	0/100mls	2/100mls	1/14/26	11:00 AM	JC	SM 9222B
Standard plate count:	0/ml	200/ml	1/13/26	5:15 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	7.8 SU	7.2 - 7.8 SU	1/13/26	1:47 PM	SL	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	1/13/26	1:47 PM	SL	DPD
Turbidity:	1 NTU	1 - 2 NTU	1/13/26	1:47 PM	SL	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor