



Dreams Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

PPS

Lab# 253

Customer

Facility Name: Perry Traditional Academy

Address: 3875 Perrysville Ave.
Pittsburgh, PA 15214

Matrix: Recreational Water

Source Type: Pool Shallow

Sample Collection

Date: 7/23/25

Time: 1:20 PM

Method: Grab

Sample Final Analysis

Date: 7/25/25

Time: 2:00 PM

Analyst: AS

Accredited Analysis	Results	Rating	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	A	7/23/25	4:27 PM	SL	SM 9222G
Total coliforms:	0/100mls	A	7/23/25	4:27 PM	SL	SM 9222B
Standard plate count:	0/ml	A	7/23/25	4:27 PM	SL	SM 9215B

Field Analysis	Results	Rating	Date/Time		Analyst	Method
pH:	7.8 SU	C	7/23/25	1:20 PM	CW	DPD
Chlorine:	4.0 mg/l	B	7/23/25	1:20 PM	CW	DPD
Turbidity:	1 NTU	A	7/23/25	1:20 PM	CW	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dreams Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

PPS

Lab# 253

Customer

Facility Name: *Perry Traditional Academy*

Address: *3875 Perrysville Ave.
Pittsburgh, PA 15214*

Matrix: *Recreational Water*

Source Type: *Pool Shallow*

Sample Collection

Date: *7/23/25*

Time: *1:20 PM*

Method: *Grab*

Sample Final Analysis

Date: *7/25/25*

Time: *2:00 PM*

Analyst: *AS*

Accredited Analysis	Results	Rating	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	A	7/23/25	4:27 PM	SL	SM 9222G
Total coliforms:	0/100mls	A	7/23/25	4:27 PM	SL	SM 9222B
Standard plate count:	0/ml	A	7/23/25	4:27 PM	SL	SM 9215B

Field Analysis	Results	Rating	Date/Time		Analyst	Method
pH:	7.8 SU	C	7/23/25	1:20 PM	CW	DPD
Chlorine:	4.0 mg/l	B	7/23/25	1:20 PM	CW	DPD
Turbidity:	1 NTU	A	7/23/25	1:20 PM	CW	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor