

Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661-7665 **Laboratory Analysis Report**

Lab ID No. 02-04041

E - 12

Lab# 2168

Customer

Facility Name: Edgewood C.C.

Address:

100 Churchill Road

Pittsburgh, PA 15235

Matrix:

Recreational Water

Source Type: Baby Pool Method: Grab

Sample Collection

Sample Final Analysis Date: Time:

Date:

Time:

6/5/25 9:30 AM

Analyst:

AS

Analyst Method

6/2/25

12:30 PM

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/3/25	9:15 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/3/25	9:15 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	6/2/25	3:25 PM	АН	SM 9215B

Field Analysis	Results	Reporting limit		Date/Time	Analyst	Method
pH:	7.8 SU	7.2 - 7.8 SU	6/2/25	12:30 PM	EH	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	6/2/25	12:30 PM	EH	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/2/25	12:30 PM	EH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

andre Smith

Andre Smith, Lead Supervisor



Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661-7665 **Laboratory Analysis Report**

Lab ID No. 02-04041

E - 12

Lab# 2168

Customer

Facility Name: Edgewood C.C.

Address:

100 Churchill Road

Pittsburgh, PA 15235

Matrix:

Recreational Water

Source Type: Baby Pool Method: Grab

Sample Collection

Sample Final Analysis Date: Time:

Date:

Time:

6/5/25 9:30 AM

Analyst:

AS

Analyst Method

6/2/25

12:30 PM

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/3/25	9:15 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/3/25	9:15 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	6/2/25	3:25 PM	АН	SM 9215B

Field Analysis	Results	Reporting limit		Date/Time	Analyst	Method
pH:	7.8 SU	7.2 - 7.8 SU	6/2/25	12:30 PM	EH	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	6/2/25	12:30 PM	EH	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/2/25	12:30 PM	EH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

andre Smith

Andre Smith, Lead Supervisor