



Dreams Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

PPS

Lab# 212

Customer

Facility Name: Langley High School
Address: 2940 Sheradan Blvd.
Pittsburgh, PA 15204

Matrix: Recreational Water
Source Type: Pool Deep

Sample Collection

Date: 9/2/25
Time: 1:58 PM
Method: Grab

Sample Final Analysis

Date: 9/5/25
Time: 10:00 AM
Analyst: AS

Accredited Analysis	Results	Rating	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	A	9/3/25	11:00 AM	SL	SM 9222G
Total coliforms:	0/100mls	A	9/3/25	11:00 AM	SL	SM 9222B
Standard plate count:	0/ml	A	9/2/25	4:50 PM	AS	SM 9215B

Field Analysis	Results	Rating	Date/Time		Analyst	Method
pH:	7.4 SU	A	9/2/25	1:58 PM	MM	DPD
Chlorine:	3.0 mg/l	A	9/2/25	1:58 PM	MM	DPD
Turbidity:	1 NTU	A	9/2/25	1:58 PM	MM	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor