



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**N-3**

**Lab# 351**

**Customer**

**Facility Name:** YMCA  
**Address:** 5021 Freeport Rd.  
Natrona Heights, PA 15065

**Sample Collection**

**Date:** 9/4/25  
**Time:** 10:12 AM  
**Method:** Grab

**Matrix:** Recreational Water

**Source Type:** Pool Deep

**Sample Final Analysis**

**Date:** 9/6/25  
**Time:** 2:00 PM  
**Analyst:** AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	9/4/25	4:30 PM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	9/4/25	4:30 PM	AS	SM 9222B
Standard plate count:	0/ml	200/ml	9/4/25	4:30 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	9/4/25	10:12 AM	SL	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	9/4/25	10:12 AM	SL	DPD
Turbidity:	1 NTU	1 - 2 NTU	9/4/25	10:12 AM	SL	Visual

**Sample comments**

*Andre Smith*

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor