



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**N-13**

**Lab# 247**

**Customer**

Facility Name: Oxford Athletic  
Address: 100 Village Club Dr.  
Wexford, PA 15090

Matrix: Recreational Water

Source Type: Spa

**Sample Collection**

Date: 8/4/25  
Time: 2:23 PM  
Method: Grab

**Sample Final Analysis**

Date: 8/7/25  
Time: 11:20 AM  
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
---------------------	---------	-----------------	----------------------	---------	--------

Escherichia Coli:	Absent	Absent	8/5/25	10:50 AM	AS	SM 9222G
-------------------	--------	--------	--------	----------	----	----------

Total coliforms:	0/100mls	2/100mls	8/5/25	10:50 AM	AS	SM 9222B
------------------	----------	----------	--------	----------	----	----------

Standard plate count:	0/ml	200/ml	8/4/25	4:55 PM	AH	SM 9215B
-----------------------	------	--------	--------	---------	----	----------

Additional Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
---------------------	---------	-----------------	----------------------	---------	--------

Fecal Streptococcus	0/100mls	2/100mls	8/5/25	1:45 PM	AH	SM 9230C
---------------------	----------	----------	--------	---------	----	----------

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
----------------	---------	-----------------	-----------	---------	--------

pH:	8.0 SU	7.2 - 7.8 SU	8/4/25	2:23 PM	MM	DPD
-----	--------	--------------	--------	---------	----	-----

Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	8/4/25	2:23 PM	MM	DPD
-----------	----------	----------------	--------	---------	----	-----

Turbidity:	1 NTU	1 - 2 NTU	8/4/25	2:23 PM	MM	Visual
------------	-------	-----------	--------	---------	----	--------

**Sample comments**

*Andre Smith*

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**N-13**

**Lab# 247**

**Customer**

**Facility Name:** Oxford Athletic  
**Address:** 100 Village Club Dr.  
Wexford, PA 15090

**Matrix:** Recreational Water  
**Source Type:** Spa

**Sample Collection**

**Date:** 8/4/25  
**Time:** 2:23 PM  
**Method:** Grab

**Sample Final Analysis**

**Date:** 8/7/25  
**Time:** 11:20 AM  
**Analyst:** AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
---------------------	---------	-----------------	----------------------	---------	--------

Escherichia Coli:	Absent	Absent	8/5/25	10:50 AM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/5/25	10:50 AM	AS	SM 9222B
Standard plate count:	0/ml	200/ml	8/4/25	4:55 PM	AH	SM 9215B

Additional Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
---------------------	---------	-----------------	----------------------	---------	--------

Fecal Streptococcus	0/100mls	2/100mls	8/5/25	1:45 PM	AH	SM 9230C
---------------------	----------	----------	--------	---------	----	----------

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
----------------	---------	-----------------	-----------	---------	--------

pH:	8.0 SU	7.2 - 7.8 SU	8/4/25	2:23 PM	MM	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	8/4/25	2:23 PM	MM	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/4/25	2:23 PM	MM	Visual

**Sample comments**

*Andre Smith*

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor