



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-15

Lab# 153

Customer

Facility Name: *Hilton Garden Inn*
Address: *2000 Garden View Ln.*
Cranberry, PA 16066

Matrix: *Recreational Water*

Source Type: *Pool*

Sample Collection

Date: *6/24/25*
Time: *11:09 AM*
Method: *Grab*

Sample Final Analysis

Date: *6/27/25*
Time: *9:20 AM*
Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/25/25	12:00 PM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/25/25	12:00 PM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	6/24/25	5:15 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	6/24/25	11:09 AM	ZR	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	6/24/25	11:09 AM	ZR	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/24/25	11:09 AM	ZR	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-15

Lab# 153

Customer

Facility Name: *Hilton Garden Inn*
Address: *2000 Garden View Ln.*
Cranberry, PA 16066

Matrix: *Recreational Water*

Source Type: *Pool*

Sample Collection

Date: *6/24/25*
Time: *11:09 AM*
Method: *Grab*

Sample Final Analysis

Date: *6/27/25*
Time: *9:20 AM*
Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/25/25	12:00 PM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/25/25	12:00 PM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	6/24/25	5:15 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	6/24/25	11:09 AM	ZR	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	6/24/25	11:09 AM	ZR	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/24/25	11:09 AM	ZR	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor