



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-11

Lab# 085

Customer

Facility Name: *Deer Lakes H.S.*

Address: *163 East Union Road*
Cheswick, PA 15024

Matrix: *Recreational Water*

Source Type: *Shallow End*

Sample Collection

Date: *8/26/25*
Time: *2:15 PM*
Method: *Grab*

Sample Final Analysis

Date: *8/29/25*
Time: *10:30 AM*
Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/27/25	11:00 AM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/27/25	11:00 AM	AS	SM 9222B
Standard plate count:	0/ml	200/ml	8/26/25	4:55 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.0 SU	7.2 - 7.8 SU	8/26/25	2:15 PM	SH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	8/26/25	2:15 PM	SH	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/26/25	2:15 PM	SH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor