



**Dream Pools And Spas  
1105 Washington Blvd  
Pittsburgh, Pennsylvania 15206  
(412) 661- 7665  
Laboratory Analysis Report**

Lab ID No. 02-04041

APM 1

**Lab# 2756**

## **Customer**

*American Pools Management  
3261 Babcock Blvd.  
Pittsburgh, PA 15237*

<b>Facility Name:</b>	<i>Artisan at Robinson</i>	<b>Date:</b>	<i>8/5/25</i>
<b>Address:</b>	<i>301 Hightower Blvd. Pittsburgh, PA 15205</i>	<b>Time:</b>	<i>7:45 AM</i>
<b>Matrix:</b>	<i>Recreational Water</i>	<b>Method:</b>	<i>Grab</i>
<b>Source Type:</b>	<i>Pool</i>	<b><u>Sample Final Analysis</u></b>	
			<b>Date:</b> <i>8/8/25</i>
			<b>Time:</b> <i>8:30 AM</i>
			<b>Analyst:</b> <i>AS</i>

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/6/25	9:20 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/6/25	9:20 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	8/5/25	4:00 PM	AS	SM 9215B
Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	8/5/25	7:45 AM	VH	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	8/5/25	7:45 AM	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/5/25	7:45 AM	VH	Visual

## Sample comments

( When exceeding reporting limit pool or spa is unfit)

Anabee Smith

Andre Smith, Lead Supervisor



**Dream Pools And Spas  
1105 Washington Blvd  
Pittsburgh, Pennsylvania 15206  
(412) 661- 7665  
Laboratory Analysis Report**

Lab ID No. 02-04041

APM 1

**Lab# 2756**

## **Customer**

*American Pools Management  
3261 Babcock Blvd.  
Pittsburgh, PA 15237*

<b>Facility Name:</b>	<i>Artisan at Robinson</i>	<b>Date:</b>	<i>8/5/25</i>
<b>Address:</b>	<i>301 Hightower Blvd. Pittsburgh, PA 15205</i>	<b>Time:</b>	<i>7:45 AM</i>
<b>Matrix:</b>	<i>Recreational Water</i>	<b>Method:</b>	<i>Grab</i>
<b>Source Type:</b>	<i>Pool</i>	<b><u>Sample Final Analysis</u></b>	
			<b>Date:</b> <i>8/8/25</i>
			<b>Time:</b> <i>8:30 AM</i>
			<b>Analyst:</b> <i>AS</i>

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/6/25	9:20 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/6/25	9:20 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	8/5/25	4:00 PM	AS	SM 9215B
Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	8/5/25	7:45 AM	VH	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	8/5/25	7:45 AM	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/5/25	7:45 AM	VH	Visual

## Sample comments

( When exceeding reporting limit pool or spa is unfit)

Annie Smith

Andre Smith, Lead Supervisor