



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**N-2**

**Lab# 234**

**Customer**

Facility Name: North Allegheny High School

Address: 10375 Perry Hwy.  
Wexford, PA 15090

Matrix: Recreational Water

Source Type: Pool Deep

**Sample Collection**

Date: 9/3/25

Time: 9:30 AM

Method: Grab

**Sample Final Analysis**

Date: 9/6/25

Time: 2:00 PM

Analyst: AS

| Accredited Analysis   | Results  | Reporting limit | Incubation Date/Time |         | Analyst | Method   |
|-----------------------|----------|-----------------|----------------------|---------|---------|----------|
| Escherichia Coli:     | Absent   | Absent          | 9/4/25               | 9:15 AM | JC      | SM 9222G |
| Total coliforms:      | 0/100mls | 2/100mls        | 9/4/25               | 9:15 AM | JC      | SM 9222B |
| Standard plate count: | 0/ml     | 200/ml          | 9/3/25               | 3:10 PM | SL      | SM 9215B |

| Field Analysis | Results  | Reporting limit | Date/Time |         | Analyst | Method |
|----------------|----------|-----------------|-----------|---------|---------|--------|
| pH:            | 7.4 SU   | 7.2 - 7.8 SU    | 9/3/25    | 9:30 AM | VH      | DPD    |
| Chlorine:      | 3.0 mg/l | 1.0 - 5.0 mg/l  | 9/3/25    | 9:30 AM | VH      | DPD    |
| Turbidity:     | 1 NTU    | 1 - 2 NTU       | 9/3/25    | 9:30 AM | VH      | Visual |

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor