



1105 Washington Blvd  
Pittsburgh, Pennsylvania 15206  
(412) 661- 7665  
Laboratory Analysis Report

Lab ID No. 02-04041

N-10

Lab# 450

**Customer**

Facility Name: Gold Fish  
Address: 1115 Freeport Rd.  
Fox Chapel, PA 15238

**Sample Collection**

Date: 5/28/25  
Time: 10:00 AM  
Method: Grab

Matrix: Recreational Water

**Sample Final Analysis**

Date: 5/31/25  
Time: 9:30 AM  
Analyst: AS

Source Type: Pool

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	5/29/25	9:30 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	5/29/25	9:30 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	5/28/25	3:50 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	5/28/25	10:00 AM	BH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	5/28/25	10:00 AM	BH	DPD
Turbidity:	1 NTU	1 - 2 NTU	5/28/25	10:00 AM	BH	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



1105 Washington Blvd  
Pittsburgh, Pennsylvania 15206  
(412) 661- 7665  
Laboratory Analysis Report

Lab ID No. 02-04041

N-10

Lab# 450

**Customer**

Facility Name: Gold Fish  
Address: 1115 Freeport Rd.  
Fox Chapel, PA 15238

**Sample Collection**

Date: 5/28/25  
Time: 10:00 AM  
Method: Grab

Matrix: Recreational Water

**Sample Final Analysis**

Date: 5/31/25  
Time: 9:30 AM  
Analyst: AS

Source Type: Pool

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	5/29/25	9:30 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	5/29/25	9:30 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	5/28/25	3:50 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	5/28/25	10:00 AM	BH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	5/28/25	10:00 AM	BH	DPD
Turbidity:	1 NTU	1 - 2 NTU	5/28/25	10:00 AM	BH	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor