



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-3

Lab# 404

Customer

Facility Name: Wilfred R.Cameron Wellness Center

Address: 240 Wellness Way
Washington, PA 15301

Matrix: Recreational Water

Source Type: Spa

Sample Collection

Date: 9/15/25

Time: 9:45 AM

Method: Grab

Sample Final Analysis

Date: 9/18/25

Time: 9:00 AM

Analyst: AS

| Accredited Analysis | Results | Reporting limit | Incubation | Date/Time | Analyst | Method |
|-----------------------|----------|-----------------|------------|-----------|---------|----------|
| Escherichia Coli: | Absent | Absent | 9/16/25 | 9:00 AM | JC | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 9/16/25 | 9:00 AM | JC | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 9/15/25 | 3:30 PM | AS | SM 9215B |

| Additional Analysis | Results | Reporting limit | Incubation | Date/Time | Analyst | Method |
|---------------------|----------|-----------------|------------|-----------|---------|----------|
| Fecal Streptococcus | 0/100mls | 2/100mls | 9/16/25 | 10:20 AM | JC | SM 9230C |

| Field Analysis | Results | Reporting limit | Date/Time | | Analyst | Method |
|----------------|----------|-----------------|-----------|---------|---------|--------|
| pH: | 7.4 SU | 7.2 - 7.8 SU | 9/15/25 | 9:45 AM | GR | DPD |
| Chlorine: | 7.5 mg/l | 1.0 - 5.0 mg/l | 9/15/25 | 9:45 AM | GR | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 9/15/25 | 9:45 AM | GR | Visual |

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor