



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**N-17**

**Lab# 2011**

**Customer**

*Facility Name:* Alameda Park

*Address:* 184 Alameda Park Road  
Butler, PA 16001

*Matrix:* Recreational Water

*Source Type:* Pool

**Sample Collection**

*Date:* 8/4/25

*Time:* 12:40 PM

*Method:* Grab

**Sample Final Analysis**

*Date:* 8/7/25

*Time:* 11:20 AM

*Analyst:* AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/5/25	11:50 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/5/25	11:50 AM	AH	SM 9222B
Standard plate count:	5700/ml	200/ml	8/4/25	5:30 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	8/4/25	12:40 PM	BH	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	8/4/25	12:40 PM	BH	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/4/25	12:40 PM	BH	Visual

**Sample comments**

*Andre Smith*

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**N-17**

**Lab# 2011**

**Customer**

**Facility Name:** Alameda Park  
**Address:** 184 Alameda Park Road  
Butler, PA 16001

**Sample Collection**

**Date:** 8/4/25  
**Time:** 12:40 PM  
**Method:** Grab

**Sample Final Analysis**

**Date:** 8/7/25  
**Time:** 11:20 AM  
**Analyst:** AS

**Matrix:** Recreational Water  
**Source Type:** Pool

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/5/25	11:50 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/5/25	11:50 AM	AH	SM 9222B
Standard plate count:	5700/ml	200/ml	8/4/25	5:30 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	8/4/25	12:40 PM	BH	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	8/4/25	12:40 PM	BH	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/4/25	12:40 PM	BH	Visual

**Sample comments**

*Andre Smith*

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor