



Dream Pools And Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 2

Lab# 2248

Customer *American Pools Management*
3261 Babcock Blvd.
Pittsburgh, PA 15237

Sample Collection

Facility Name: *Hickory Heights*
Address: *118 Hickory Heights Dr.*
Bridgeville, PA 15017

Date: 6/9/25
Time: 12:42 PM
Method: Grab

Sample Final Analysis

Matrix: *Recreational Water*
Source Type: *Wading Pool*

Date: 6/12/25
Time: 9:30 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	6/10/25 10:10 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/10/25 10:10 AM	EB	SM 9222B
Standard plate count:	98/ml	200/ml	6/9/25 5:00 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	6/9/25 12:42 PM	AF	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	6/9/25 12:42 PM	AF	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/9/25 12:42 PM	AF	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dream Pools And Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 2

Lab# 2248

Customer *American Pools Management*
3261 Babcock Blvd.
Pittsburgh, PA 15237

Sample Collection

Facility Name: *Hickory Heights*
Address: *118 Hickory Heights Dr.*
Bridgeville, PA 15017

Date: 6/9/25
Time: 12:42 PM
Method: Grab

Sample Final Analysis

Matrix: *Recreational Water*
Source Type: *Wading Pool*

Date: 6/12/25
Time: 9:30 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	6/10/25 10:10 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/10/25 10:10 AM	EB	SM 9222B
Standard plate count:	98/ml	200/ml	6/9/25 5:00 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	6/9/25 12:42 PM	AF	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	6/9/25 12:42 PM	AF	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/9/25 12:42 PM	AF	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor