



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**N-3**

**Lab# 146**

**Customer**

Facility Name: Highland High School  
Address: 1500 Pacific Ave.  
Natrona Heights, PA 15065

**Sample Collection**

Date: 9/9/25  
Time: 1:46 PM  
Method: Grab

Matrix: Recreational Water  
Source Type: Pool Deep

**Sample Final Analysis**

Date: 9/12/25  
Time: 10:00 AM  
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	9/10/25	10:00 AM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	9/10/25	10:00 AM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	9/9/25	4:30 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.8 SU	7.2 - 7.8 SU	9/9/25	1:46 PM	AMH	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	9/9/25	1:46 PM	AMH	DPD
Turbidity:	1 NTU	1 - 2 NTU	9/9/25	1:46 PM	AMH	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor