



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661-7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

W-1

Lab# 228

| <u>Customer</u>       |   | <u>Sample Collection</u>     |                      |         |        |          |
|-----------------------|---|------------------------------|----------------------|---------|--------|----------|
| Facility Name:        | Montour High School                       | Date:                        | 10/20/25             |         |        |          |
| Address:              | 223 Clever Rd.<br>Mc Kees Rocks, PA 15136 | Time:                        | 8:21 AM              |         |        |          |
| Matrix:               |   | <u>Sample Final Analysis</u> |                      |         |        |          |
| Source Type:          | Recreational Water                        | Date:                        | 10/23/25             |         |        |          |
|                       | Deep End                                  | Time:                        | 10:00 AM             |         |        |          |
|                       |   | Analyst:                     | AS                   |         |        |          |
| Accredited Analysis   | Results                                   | Reporting limit              | Incubation Date/Time | Analyst | Method |          |
| Escherichia Coli:     | Absent                                    | Absent                       | 10/21/25             | 9:30 AM | SL     | SM 9222G |
| Total coliforms:      | 0/100mls                                  | 2/100mls                     | 10/21/25             | 9:30 AM | SL     | SM 9222B |
| Standard plate count: | 0/ml                                      | 200/ml                       | 10/20/25             | 5:04 PM | SL     | SM 9215B |
| Field Analysis        | Results                                   | Reporting limit              | Date/Time            | Analyst | Method |          |
| pH:                   | 7.8 SU                                    | 7.2 - 7.8 SU                 | 10/20/25             | 8:21 AM | AMH    | DPD      |
| Chlorine:             | 2.0 mg/l                                  | 1.0 - 5.0 mg/l               | 10/20/25             | 8:21 AM | AMH    | DPD      |
| Turbidity:            | 1 NTU                                     | 1 - 2 NTU                    | 10/20/25             | 8:21 AM | AMH    | Visual   |

Sample comments

*Andre Smith*

( When exceeding reporting limit pool or spa is unfit)

\_\_\_\_\_  
Andre Smith, Lead Supervisor