



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**C-1**

**Lab# 262**

**Customer**

Facility Name: *Rehabilitation Institute*

Address: *1405 Shady Ave.  
Pittsburgh, PA 15217*

Matrix: *Recreational Water*

Source Type: *Pool - Sm*

**Sample Collection**

Date: *9/9/25*

Time: *8:37 AM*

Method: *Grab*

**Sample Final Analysis**

Date: *9/12/25*

Time: *10:00 AM*

Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	9/10/25	9:30 AM	JC	SM 9222G
Total coliforms:	0/100mls	2/100mls	9/10/25	9:30 AM	JC	SM 9222B
Standard plate count:	0/ml	200/ml	9/9/25	2:30 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	9/9/25	8:37 AM	GR	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	9/9/25	8:37 AM	GR	DPD
Turbidity:	1 NTU	1 - 2 NTU	9/9/25	8:37 AM	GR	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor