Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

SERVICE

Lab# 2041

Customer		*Sample Collection*	
Facility Name:	*Berkshire Estate*	*Date:*	*8/12/25*
		Time:	*8:28 AM*
Address:	*6000 Middle Field Dr.*	*Method:*	*Grab*
	McDonald, PA 15057		
		Sample Final Analysis	
Matrix:	*Recreational Water*	*Date:*	*8/15/25*
		Time:	*9:00 AM*
Source Type:	*Baby Pool*	*Analyst:*	*AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/13/25	10:30 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/13/25	10:30 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	8/12/25	3:58 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	8/12/25	8:28 AM	AH	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	8/12/25	8:28 AM	AH	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/12/25	8:28 AM	AH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

_____

Andre Smith, Lead Supervisor

Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

SERVICE

Lab# 2041

Customer

Facility Name:	*Berkshire Estate*
Address:	*6000 Middle Field Dr.* *McDonald, PA 15057*
Matrix:	*Recreational Water*
Source Type:	*Baby Pool*

Sample Collection

Date:	*8/12/25*
Time:	*8:28 AM*
Method:	*Grab*

Sample Final Analysis

Date:	*8/15/25*
Time:	*9:00 AM*
Analyst:	*AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/13/25	10:30 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/13/25	10:30 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	8/12/25	3:58 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	8/12/25	8:28 AM	AH	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	8/12/25	8:28 AM	AH	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/12/25	8:28 AM	AH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor