



Dream Pools and Spas  
1105 Washington Blvd  
Pittsburgh, Pennsylvania 15206  
(412) 661- 7665

Lab ID No. 02-04041

W-2

Lab# 066

## Laboratory Analysis Report

### Customer

Facility Name: Comfort Suite  
Address: 750 Aten Rd.  
Coraopolis, PA 15108

Matrix: Recreational Water

Source Type: Pool

### Sample Collection

Date: 11/11/25  
Time: 9:00 AM  
Method: Grab

### Sample Final Analysis

Date: 11/14/25  
Time: 10:00 AM  
Analyst: AS

| Accredited Analysis   | Results  | Reporting limit | Incubation | Date/Time | Analyst | Method   |
|-----------------------|----------|-----------------|------------|-----------|---------|----------|
| Escherichia Coli:     | Absent   | Absent          | 11/12/25   | 9:30 AM   | SL      | SM 9222G |
| Total coliforms:      | 0/100mls | 2/100mls        | 11/12/25   | 9:30 AM   | SL      | SM 9222B |
| Standard plate count: | 0/ml     | 200/ml          | 11/11/25   | 2:30 PM   | SL      | SM 9215B |

| Field Analysis | Results  | Reporting limit | Date/Time |         | Analyst | Method |
|----------------|----------|-----------------|-----------|---------|---------|--------|
| pH:            | 8.0 SU   | 7.2 - 7.8 SU    | 11/11/25  | 9:00 AM | VH      | DPD    |
| Chlorine:      | 1.0 mg/l | 1.0 - 5.0 mg/l  | 11/11/25  | 9:00 AM | VH      | DPD    |
| Turbidity:     | 1 NTU    | 1 - 2 NTU       | 11/11/25  | 9:00 AM | VH      | Visual |

### Sample comments

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor