



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-16

Lab# 290

Customer

Facility Name: Springhill Suites
Address: 16 Trinity Point Drive
Washington, PA 15301

Sample Collection

Date: 6/11/25
Time: 11:14 AM
Method: Grab

Matrix: Recreational Water
Source Type: Pool

Sample Final Analysis

Date: 6/13/25
Time: 3:00 PM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/11/25	5:30 PM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/11/25	5:30 PM	SL	SM 9222B
Standard plate count:	180/ml	200/ml	6/11/25	5:30 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.2 SU	7.2 - 7.8 SU	6/11/25	11:14 AM	CW	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	6/11/25	11:14 AM	CW	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/11/25	11:14 AM	CW	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-16

Lab# 290

Customer

Facility Name: Springhill Suites
Address: 16 Trinity Point Drive
Washington, PA 15301

Sample Collection

Date: 6/11/25
Time: 11:14 AM
Method: Grab

Matrix: Recreational Water
Source Type: Pool

Sample Final Analysis

Date: 6/13/25
Time: 3:00 PM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/11/25	5:30 PM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/11/25	5:30 PM	SL	SM 9222B
Standard plate count:	180/ml	200/ml	6/11/25	5:30 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.2 SU	7.2 - 7.8 SU	6/11/25	11:14 AM	CW	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	6/11/25	11:14 AM	CW	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/11/25	11:14 AM	CW	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor