



Dreams Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

PPS

Lab# 244

Customer

Facility Name: Oliver H.S.

Address: 2323 Brighton Rd.
Pittsburgh, PA 15212

Matrix: Recreational Water

Source Type: Pool Shallow

Sample Collection

Date: 9/29/25
Time: 10:32 AM
Method: Grab

Sample Final Analysis

Date: 10/2/25
Time: 10:30 AM
Analyst: AS

Accredited Analysis	Results	Rating	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	A	9/30/25	10:10 AM	JC	SM 9222G
Total coliforms:	0/100mls	A	9/30/25	10:10 AM	JC	SM 9222B
Standard plate count:	0/ml	A	9/29/25	5:10 PM	SL	SM 9215B

Field Analysis	Results	Rating	Date/Time		Analyst	Method
pH:	7.6 SU	A	9/29/25	10:32 AM	MM	DPD
Chlorine:	3.0 mg/l	B	9/29/25	10:32 AM	MM	DPD
Turbidity:	1 NTU	A	9/29/25	10:32 AM	MM	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor