



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-1

Lab# 193

Customer

Facility Name: *Keystone Oaks High School*

Address: *1000 Kelton Ave.*
Pittsburgh, PA 15216

Matrix: *Recreational Water*

Source Type: *Pool Deep*

Sample Collection

Date: *9/9/25*

Time: *10:50 AM*

Method: *Grab*

Sample Final Analysis

Date: *9/12/25*

Time: *10:00 AM*

Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	9/10/25 10:10 AM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	9/10/25 10:10 AM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	9/9/25 5:50 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	9/9/25 10:50 AM	MM	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	9/9/25 10:50 AM	MM	DPD
Turbidity:	1 NTU	1 - 2 NTU	9/9/25 10:50 AM	MM	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor