



Dreams Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

PPS

Lab# 058

Customer

Facility Name: Colfax Elementary

Address: 2332 Beechwood Blvd.
Pittsburgh, PA 15217

Matrix: Recreational Water

Source Type: Pool Deep

Sample Collection

Date: 9/2/25

Time: 11:32 AM

Method: Grab

Sample Final Analysis

Date: 9/5/25

Time: 10:00 AM

Analyst: AS

Accredited Analysis	Results	Rating	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	A	9/3/25	11:00 AM	SL	SM 9222G
Total coliforms:	0/100mls	A	9/3/25	11:00 AM	SL	SM 9222B
Standard plate count:	0/ml	A	9/2/25	4:50 PM	AS	SM 9215B

Field Analysis	Results	Rating	Date/Time	Analyst	Method	
pH:	7.6 SU	A	9/2/25	11:32 AM	MM	DPD
Chlorine:	2.0 mg/l	B	9/2/25	11:32 AM	MM	DPD
Turbidity:	1 NTU	A	9/2/25	11:32 AM	MM	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor