



**Dreams Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**PPS**

**Lab# 252**

**Customer**

Facility Name: Perry Traditional Academy

Address: 3875 Perrysville Ave.  
Pittsburgh, PA 15214

Matrix: Recreational Water

Source Type: Pool Deep

**Sample Collection**

Date: 9/2/25

Time: 2:59 PM

Method: Grab

**Sample Final Analysis**

Date: 9/5/25

Time: 10:00 AM

Analyst: AS

Accredited Analysis	Results	Rating	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	A	9/3/25	11:00 AM	SL	SM 9222G
Total coliforms:	0/100mls	A	9/3/25	11:00 AM	SL	SM 9222B
Standard plate count:	0/ml	A	9/2/25	4:50 PM	AS	SM 9215B

Field Analysis	Results	Rating	Date/Time		Analyst	Method
pH:	7.8 SU	C	9/2/25	2:59 PM	MM	DPD
Chlorine:	3.0 mg/l	A	9/2/25	2:59 PM	MM	DPD
Turbidity:	1 NTU	A	9/2/25	2:59 PM	MM	Visual

**Sample comments**

*Andre Smith*

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor