

Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

APM 3

Lab# 2373

Customer American Pools Management

3261 Babcock Blvd. Pittsburgh, PA 15237

Facility Name: Nob Hill

Address: 3000 Swallow Hill Rd.

Pittsburgh, PA 15220

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 6/23/25

Time: 12:29 PM Method: Grab

Sample Final Analysis

Date: 6/26/25 Time: 9:00 AM

Time: 9:00 AM Analyst: AS

Accredited Analysis	Results Reportin	Reporting limit	nit Incubation	Date/Time	Analyst	Method	
Escherichia Coli:	Absent	Absent	6/24/25	11:10 AM	ЕВ	SM 9222G	
Total coliforms:	0/100mls	2/100mls	6/24/25	11:10 AM	EB	SM 9222B	
Standard plate count:	0/ml	200/ml	6/23/25	6:00 PM	EB	SM 9215B	

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	6/23/25	12:29 PM	CW	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	6/23/25	12:29 PM	CW	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/23/25	12:29 PM	CW	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

andre Smith

Andre Smith, Lead Supervisor



Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

APM 3

Lab# 2373

Customer American Pools Management

3261 Babcock Blvd. Pittsburgh, PA 15237

Facility Name: Nob Hill

Address: 3000 Swallow Hill Rd.

Pittsburgh, PA 15220

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 6/23/25

Time: 12:29 PM Method: Grab

Sample Final Analysis

Date: 6/26/25 Time: 9:00 AM

Time: 9:00 AM Analyst: AS

Accredited Analysis	Results Reportin	Reporting limit	nit Incubation	Date/Time	Analyst	Method	
Escherichia Coli:	Absent	Absent	6/24/25	11:10 AM	ЕВ	SM 9222G	
Total coliforms:	0/100mls	2/100mls	6/24/25	11:10 AM	EB	SM 9222B	
Standard plate count:	0/ml	200/ml	6/23/25	6:00 PM	EB	SM 9215B	

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	6/23/25	12:29 PM	CW	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	6/23/25	12:29 PM	CW	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/23/25	12:29 PM	CW	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

andre Smith

Andre Smith, Lead Supervisor