Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-13

Lab# 2674

Customer		**Sample Collection**	
Facility Name:	*Clarion Hotel - Belle Vernon*	*Date:*	*8/4/25*
		Time:	10:30 AM
Address:	*827 Finley Rd*	*Method:*	*Grab*
	Belle Vernon, PA 15012		
		Sample Final Analysis	
Matrix:	*Recreational Water*	*Date:*	*8/7/25*
		Time:	11:20 AM
Source Type:	*Pool*	*Analyst:*	*AS*

Accredited Analysis	**Results**	**Reporting limit**	**Incubation Date/Time**		**Analyst**	**Method**
Escherichia Coli:	Absent	Absent	8/5/25	11:50 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/5/25	11:50 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	8/4/25	5:30 PM	AS	SM 9215B

Field Analysis	**Results**	**Reporting limit**	**Date/Time**		**Analyst**	**Method**
pH:	7.0 SU	7.2 - 7.8 SU	8/4/25	10:30 AM	SH	DPD
Chlorine:	7.5 mg/l	1.0 - 5.0 mg/l	8/4/25	10:30 AM	SH	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/4/25	10:30 AM	SH	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor

Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-13

Lab# 2674

Customer

		Sample Collection	
Facility Name:	*Clarion Hotel - Belle Vernon*	*Date:*	*8/4/25*
		Time:	10:30 AM
Address:	*827 Finley Rd*	*Method:*	*Grab*
	Belle Vernon, PA 15012		
		Sample Final Analysis	
Matrix:	*Recreational Water*	*Date:*	*8/7/25*
		Time:	*11:20 AM*
Source Type:	*Pool*	*Analyst:*	*AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/5/25	11:50 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/5/25	11:50 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	8/4/25	5:30 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.0 SU	7.2 - 7.8 SU	8/4/25	10:30 AM	SH	DPD
Chlorine:	7.5 mg/l	1.0 - 5.0 mg/l	8/4/25	10:30 AM	SH	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/4/25	10:30 AM	SH	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor