



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-15

Lab# 2636

Customer

Facility Name: Oakbrooke Estates

Address: Oakbrooke Dr.
Canonsburgh, PA 15317

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 8/19/25
Time: 3:34 PM
Method: Grab

Sample Final Analysis

Date: 8/22/25
Time: 9:00 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/20/25	11:15 AM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/20/25	11:15 AM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	8/19/25	5:20 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	8/19/25	3:34 PM	AF	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	8/19/25	3:34 PM	AF	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/19/25	3:34 PM	AF	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor