



Lab ID No. 02-04041

**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661-7665**  
**Laboratory Analysis Report**

Service

Lab# 012

<u>Customer</u>		<u>Sample Collection</u>				
Facility Name:	Atrium	Date:	2/16/26			
Address:	307 South Dithridge Pittsburgh, PA 15213	Time:	10:00 AM			
Matrix:		<u>Sample Final Analysis</u>				
Source Type:	Recreational Water	Date:	2/18/26			
		Time:	10:30 AM			
		Analyst:	AS			
Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method	
Escherichia Coli:	Absent	Absent	2/17/26	10:00 AM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	2/17/26	10:00 AM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	2/16/26	5:08 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	7.0 SU	7.2 - 7.8 SU	2/16/26	10:00 AM	AG	DPD
Chlorine:	2.8 mg/l	1.0 - 5.0 mg/l	2/16/26	10:00 AM	AG	DPD
Turbidity:	1 NTU	1 - 2 NTU	2/16/26	10:00 AM	AG	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor