



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**E-2**

**Lab# 240**

**Customer**

Facility Name: Norwin High School  
Address: 251 McMahon Dr.  
Huntingdon, PA 15642

**Sample Collection**

Date: 2/9/26  
Time: 8:30 AM  
Method: Grab

**Sample Final Analysis**

Date: 2/12/26  
Time: 10:30 AM  
Analyst: AS

Matrix: Recreational Water

Source Type: Pool

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	2/10/26 10:00 AM	JC	SM 9222G
Total coliforms:	0/100mls	2/100mls	2/10/26 10:00 AM	JC	SM 9222B
Standard plate count:	0/ml	200/ml	2/9/26 5:20 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	2/9/26 8:30 AM	JC	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	2/9/26 8:30 AM	JC	DPD
Turbidity:	1 NTU	1 - 2 NTU	2/9/26 8:30 AM	JC	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor