

Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041 W-13

Lab# 2086

<u>Customer</u> <u>Sample Collection</u>

Facility Name: Centennial Point Date: 7/8/25
Time: 1:50 PM

Address: 423 Patriot Dr. Method: Grab

Carnegie, PA 15106

Matrix: Recreational Water Sample Final Analysis

Date: 7/11/25

Source Type: Pool Time: 9:00 AM Analyst: AS

Accredited Analysis Results Reporting limit **Analyst** Method Incubation Date/Time Escherichia Coli: Absent Absent 7/9/25 9:30 AM ΕB SM 9222G Total coliforms: 0/100mls 2/100mls 7/9/25 9:30 AM EΒ SM 9222B Standard plate count: 0/ml 200/ml 7/8/25 4:30 PM AΗ SM 9215B

| Field Analysis | Results | Reporting limit | | Date/Time | Analyst | Method |
|----------------|----------|-----------------|--------|-----------|---------|--------|
| pH: | 7.5 SU | 7.2 - 7.8 SU | 7/8/25 | 1:50 PM | ZS | DPD |
| Chlorine: | 3.0 mg/l | 1.0 - 5.0 mg/l | 7/8/25 | 1:50 PM | ZS | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 7/8/25 | 1:50 PM | ZS | Visual |

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor

andre Smith



Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041 W-13

Lab# 2086

<u>Customer</u> <u>Sample Collection</u>

Facility Name: Centennial Point Date: 7/8/25
Time: 1:50 PM

Address: 423 Patriot Dr. Method: Grab

Carnegie, PA 15106

Matrix: Recreational Water Sample Final Analysis

Date: 7/11/25

Source Type: Pool Time: 9:00 AM Analyst: AS

Accredited Analysis Results Reporting limit **Analyst** Method Incubation Date/Time Escherichia Coli: Absent Absent 7/9/25 9:30 AM ΕB SM 9222G Total coliforms: 0/100mls 2/100mls 7/9/25 9:30 AM EΒ SM 9222B Standard plate count: 0/ml 200/ml 7/8/25 4:30 PM AΗ SM 9215B

| Field Analysis | Results | Reporting limit | | Date/Time | Analyst | Method |
|----------------|----------|-----------------|--------|-----------|---------|--------|
| pH: | 7.5 SU | 7.2 - 7.8 SU | 7/8/25 | 1:50 PM | ZS | DPD |
| Chlorine: | 3.0 mg/l | 1.0 - 5.0 mg/l | 7/8/25 | 1:50 PM | ZS | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 7/8/25 | 1:50 PM | ZS | Visual |

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor

andre Smith