Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

W-11

Lab# *2493*

Customer		*Sample Collection*	
Facility Name:	Sonoma Ridge	*Date:*	6/10/25
		Time:	11:00 AM
Address:	4007 Duckhorn Dr.	*Method:*	Grab
	Moon Township, PA 15108		
		Sample Final Analysis	
Matrix:	Recreational Water	*Date:*	6/13/25
		Time:	9:30 AM
Source Type:	Baby Pool	*Analyst:*	AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/11/25	9:30 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/11/25	9:30 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	6/10/25	3:12 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	6/10/25	11:00 AM	VH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	6/10/25	11:00 AM	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/10/25	11:00 AM	VH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

_____

Andre Smith, Lead Supervisor

Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

W-11

Lab# 2493

Customer		*Sample Collection*	
Facility Name:	Sonoma Ridge	*Date:*	6/10/25
		Time:	11:00 AM
Address:	4007 Duckhorn Dr.	*Method:*	Grab
	Moon Township, PA 15108		
		Sample Final Analysis	
Matrix:	Recreational Water	*Date:*	6/13/25
		Time:	9:30 AM
Source Type:	Baby Pool	*Analyst:*	AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/11/25	9:30 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/11/25	9:30 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	6/10/25	3:12 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	6/10/25	11:00 AM	VH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	6/10/25	11:00 AM	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/10/25	11:00 AM	VH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor