Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Customer			*Sample Collection*	
Facility Name:	*Ascent 430*		*Date:*	*7/7/25*
			Time:	9:41 AM
Address:	*430 Ascent Dr.*		*Method:*	*Grab*
	Marshall Twp., PA 15086			
			Sample Final Analysis	
Matrix:	*Recreational Water*		*Date:*	*7/10/25*
			Time:	*9:30 AM*
Source Type:	*Pool*		*Analyst:*	*AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/8/25	9:30 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/8/25	9:30 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	7/7/25	3:41 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.2 SU	7.2 - 7.8 SU	7/7/25	9:41 AM	ZR	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	7/7/25	9:41 AM	ZR	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/7/25	9:41 AM	ZR	Visual

Sample comments

_____

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)

Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-14

Lab# 2021

Customer

Facility Name:	*Ascent 430*
Address:	*430 Ascent Dr.*
	Marshall Twp., PA 15086
Matrix:	*Recreational Water*
Source Type:	*Pool*

Sample Collection

Date:	*7/7/25*
Time:	9:41 AM
Method:	*Grab*

Sample Final Analysis

Date:	*7/10/25*
Time:	*9:30 AM*
Analyst:	*AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/8/25	9:30 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/8/25	9:30 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	7/7/25	3:41 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.2 SU	7.2 - 7.8 SU	7/7/25	9:41 AM	ZR	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	7/7/25	9:41 AM	ZR	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/7/25	9:41 AM	ZR	Visual

Sample comments

_____

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)