



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**E-3**

**Lab# 470**

**Customer**

Facility Name: Hampton Inn  
Address: 62 Pine Ridge Rd.  
Blairsville, PA 15717

**Sample Collection**

Date: 11/10/25  
Time: 11:00 AM  
Method: Grab

Matrix: Recreational Water  
Source Type: Pool

**Sample Final Analysis**

Date: 11/13/25  
Time: 10:00 AM  
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	11/11/25	9:50 AM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	11/11/25	9:50 AM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	11/10/25	5:10 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	11/10/25	11:00 AM	DNP	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	11/10/25	11:00 AM	DNP	DPD
Turbidity:	1 NTU	1 - 2 NTU	11/10/25	11:00 AM	DNP	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor